



## AWWA C-905 Municipal Water Pipe Certification

To Whom It May Concern:

Please be advised that the North American Pipe Corporation pipe products:

AWWA C905 PVC Water Distribution Pipe, Sizes 14"-36", DR41, DR32.5, DR25, DR21, and DR18

Provided by North American Pipe Corporation is manufactured in accordance with the following standards:

*AWWA C905 Standard for Polyvinyl Chloride (PVC) Pressure Pipe and Fabricated Fittings, 14 In. Through 48 In. (350 mm Through 1,200 mm), For Water Transmission and Distribution*

*ASTM F477 Standard Specification for Elastomeric Seals (Gaskets) for Joining Plastic Pipe*

*ASTM D3139 Standard Specification for Joints for Plastic Pressure Pipes Using Flexible Elastomeric Seals*

The PVC material conforms to a cell classification of 12454 as defined by ASTM D1784 *Standard Specification for Rigid Poly(Vinyl Chloride) (PVC) Compounds and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds*. The standard pipe laying length is 20 feet. The pipe is listed by Underwriters Laboratories, approved by Factory Mutual, and is listed by NSF International to ANSI/NSF 61.

Mike Glasgow, P.E.  
Engineering and Field Services

*Quality Piping Materials*