



## ASTM D2241 IPS Gasketed Pipe Certification

To Whom It May Concern:

Please be advised that the North American Pipe Corporation pipe products:

ASTM D2241 Gasketed PVC Water Distribution Pipe, Sizes 1½"-18",  
SDR41, SDR32.5, SDR26, SDR21, SDR17, SDR13.5

Provided by North American Pipe Corporation is manufactured in accordance  
with the American Society for Testing and Materials:

*ASTM D2241 Standard Specification for Poly(Vinyl Chloride) (PVC)  
Pressure-Rated Pipe (SDR Series)*

*ASTM F477 Standard Specification for Elastomeric Seals (Gaskets) for  
Joining Plastic Pipe*

*ASTM D3139 Standard Specification for Joints for Plastic Pressure Pipes  
Using Flexible Elastomeric Seals*

The PVC material conforms to a cell classification of 12454 as defined by ASTM  
D1784 *Standard Specification for Rigid Poly(Vinyl Chloride) (PVC) Compounds  
and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds*. The standard pipe  
laying length is 20 feet. The pipe is listed by NSF International to ANSI/NSF 14  
and ANSI/NSF 61.

Mike Glasgow, P.E.  
Engineering and Field Services

*Quality Piping Materials*