



## ASTM D2241 IPS Solvent Weld Pipe Certification

To Whom It May Concern:

Please be advised that the North American Pipe Corporation pipe products:

ASTM D2241 Solvent Weld Belled End PVC Water Distribution Pipe,  
Sizes ½"-12", SDR41, SDR32.5, SDR26, SDR21, SDR17, SDR13.5

Provided by North American Pipe Corporation is manufactured in accordance with the following standards:

*ASTM D2241 Standard Specification for Poly(Vinyl Chloride) (PVC) Pressure-Rated Pipe (SDR Series)*

*ASTM D2672 Standard Specification for Joints for IPS PVC Pipe Using Solvent Cement*

The PVC material conforms to a cell classification of 12454 as defined by ASTM D1784 *Standard Specification for Rigid Poly(Vinyl Chloride) (PVC) Compounds and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds*. The standard pipe laying length is 20 feet. The pipe is Factory Mutual approved and listed by NSF International to ANSI/NSF 14 and ANSI/NSF 61.

Mike Glasgow, P.E.  
Engineering and Field Services

*Quality Piping Materials*