



## Loading Data for AWWA C-905 Municipal Water Pipe

NOMINAL PIPE SIZE	OUTSIDE DIAMETER	JOINTS PER BUNDLE	*FEET PER BUNDLE	FEET PER TRUCKLOAD
<b>PR 80 / DR 51</b>				
30"	32.0	3	60	240
36"	38.3	2	40	160
<b>PR 100 / DR 41</b>				
16"	17.4	2/3/4/6	40/60/80/120	1,000
18"	19.5	4/6	80/120	800
20"	21.6	4	80	640
24"	25.8	3	60	360
30"	32.0	3	60	240
36"	38.3	2	40	160
<b>PR 125 / DR 32.5</b>				
16"	17.4	2/3/4/6	40/60/80/120	1,000
24"	25.8	3	60	360
30"	32.0	3	60	240
36"	38.3	2	40	160
<b>PR 165 / DR 25</b>				
14"	15.3	6	120	1,440
16"	17.4	2/3/4/6	40/60/80/120	1,000
18"	19.5	4/6	80/120	800
20"	21.6	4	80	640
24"	25.8	3	60	360
30"	32.0	3	60	240
36"	38.3	2	40	160
<b>PR 200 / DR 21</b>				
14"	15.3	6	120	1,440
16"	17.4	2/3/4/6	40/60/80/120	1,000
18"	19.5	4/6	80/120	800
20"	21.6	4	80	640
24"	25.8	3	60	360
30"	32.0	3	60	240
36"	38.3	2	40	160
<b>PR 235 / DR 18</b>				
14"	15.3	6	120	1,440
16"	17.4	2/3/4/6	40/60/80/120	1,000
18"	19.5	4/6	80/120	800
20"	21.6	4	80	640
24"	25.8	3	60	360
<b>PR 305 / DR 14</b>				
14"	15.3	6	120	1,320

Note: These dimensions are for estimating purposes only \*Based on laying length of 20 feet

Rev: 11/2009