



Loading Data for AWWA C-905 PVC Pipe for Reclaimed Water Applications

NOMINAL PIPE SIZE	OUTSIDE DIAMETER	JOINTS PER BUNDLE	*FEET PER BUNDLE	FEET PER TRUCKLOAD
PR 80 / DR 51				
30"	32.0	3	60	240
36"	38.3	2	40	160
PR 100 / DR 41				
16"	17.4	2/3/4/6	40/60/80/120	1,000
18"	19.5	4/6	80/120	800
20"	21.6	4	80	640
24"	25.8	3	60	360
30"	32.0	3	60	240
36"	38.3	2	40	160
PR 125 / DR 32.5				
16"	17.4	2/3/4/6	40/60/80/120	1,000
24"	25.8	3	60	360
30"	32.0	3	60	240
36"	38.3	2	40	160
PR 165 / DR 25				
14"	15.3	6	120	1,440
16"	17.4	2/3/4/6	40/60/80/120	1,000
18"	19.5	4/6	80/120	800
20"	21.6	4	80	640
24"	25.8	3	60	360
30"	32.0	3	60	240
36"	38.3	2	40	160
PR 200 / DR 21				
14"	15.3	6	120	1,440
16"	17.4	2/3/4/6	40/60/80/120	1,000
18"	19.5	4/6	80/120	800
20"	21.6	4	80	640
24"	25.8	3	60	360
30"	32.0	3	60	240
36"	38.3	2	40	160
PR 235 / DR 18				
14"	15.3	6	120	1,440
16"	17.4	2/3/4/6	40/60/80/120	1,000
18"	19.5	4/6	80/120	800
20"	21.6	4	80	640
24"	25.8	3	60	360
PR 305 / DR 14				
14"	15.3	6	120	1,320

Note: These dimensions are for estimating purposes only *Based on laying length of 20 feet

Rev: 06/2010